

**ADDENDUM #1**

**TITLE: RE-BID: CITY OF BELLE GLADE
MAIN STREET LANDSCAPING
IMPROVEMENTS**

**BID NO: 09-2021
BID/RFP OPENING DATE: 8/3/2021 @ 3:00PM**

DATE: 7/15/2021

NUMBER OF PAGES: 1

This Addendum to the drawings, specifications and contract documents is issued to provide additional information and clarification to the original bid specifications and ITB form and is hereby declared a part of the original drawings, specifications and contract documents. In case of conflict, this Addendum shall govern.


Bidders shall acknowledge receipt of this Addendum by inserting this Addendum in the attachment section of the Bid Form.

Description: QUESTIONS

1. What type of plastic edging is specified?
 - a. **ANSWER: Black, heavy-gauge plastic edging containing UV inhibitors with a rounded top edge and v-lip bottom (anchored with poly stakes).**
2. What sizes are the plant material specified? A few of the items list container size (5 of 16).
 - a. **ANSWER: Plant sizes not specified can be assumed to be of the 5-gal planter size.**

THE BALANCE OF THIS PAGE IS INTENTIONALLY LEFT BLANK

CITY OF BELLE GLADE



Neil Appel, C.P.M.
Purchasing Manager

BIDDER

Signature

Printed, Title

COMPANY