

**ADDENDUM# 2**

**TITLE: LAKE SHORE CIVIC CENTER  
BUILDING RENOVATIONS**

**BID NO: 02-2022  
BID OPENING DATE: 4/12/22@3:00PM.**

**DATE: 4/4/22**

**NUMBER OF PAGES: 1**

**This Addendum to the drawings, specifications and contract documents is issued to provide additional information and clarification to the original bid specifications and ITB form and is hereby declared a part of the original drawings, specifications and contract documents. In case of conflict, this Addendum shall govern.**

**Bidders shall acknowledge receipt of this Addendum by inserting this Addendum in the attachment section of the Bid Form.**

**Description:**

**THE BALANCE OF THIS PAGE IS INTENTIONALLY LEFT BLANK**

1. After reviewing plans we need more information on what to do with the electrical main service. The only thing we can see that can be accomplished is the reduction of one meter.

**Electrical contractor shall remove one of the meters and demolish and remove all unused wiring and conduit.**

2. All data outlets, outside remote cameras, outside security lights have to be wired with exposed electrical conduit.

**Yes, because some walls are blocks and some are furred-out, which make it impossible**

3. Is the City going to use their own data company to terminate all data cables?

**The contractor shall be responsible terminating all data cables using a licensed contractor.**

4. Do we rewire all ceiling fixtures in the civic center auditorium to LED lighting (Because ceiling is a plastered ceiling)?

**No. Only change out the electrical component to LED and paint existing can trim.**

5. Do we replace all other 2x4 drop in fixtures with LED fixtures?

**Yes.**

**CITY OF BELLE GLADE**

A blue ink signature of Neil Appel, consisting of a stylized 'N' and 'A'.

**NEIL APPEL, C.P.M.  
PURCHASING MANAGER**

**BIDDER**

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Printed, Title**

\_\_\_\_\_  
**COMPANY**